

TEST REPORT

NO. 1671.0080.2.345

ELKIMA Elektrik Insaat Taahhüt Tic. Ltd. Sti. Kemalpasa Organize San.
 Bölgesi Ankara Asfaltı
 Atatürk Mah. 37 Sokak No: 10
 Ulucak-İZMİR

CLIENT

ELKIMA Elektrik Insaat Taahhüt Tic. Ltd. Sti. Kemalpasa Organize San.
 Bölgesi Ankara Asfaltı

MANUFACTURER

Three-phase oil transformer

TEST OBJECT

HTY 36

TYPE

201927

MANUFACTURING NO.

Rated power	1000 kVA	RATED CHARACTERISTICS GIVEN BY THE CLIENT
Rated voltage	33000 + 4.5 - 3 x 4.5 % / 400 V	
Impedance voltage	4.1 %	
Rated frequency	50 Hz	
Vector group	Dyn 11	

IEC 60076-5: 2000-07

NORMATIVE DOCUMENT

Demonstration of the ability to withstand the dynamic effects of short circuit

RANGE OF TESTS PERFORMED

19 September 2002

DATE OF TEST

The transformer has PASSED the test.

TEST RESULT

H. GLABSCH
 Head of high-power test laboratory
 Berlin, 11 October 2002

W. MORITZ
 Test engineer in charge



Independent test laboratory, accredited by Deutsche Akkreditierungsstelle Technik (DATech) e.V. in the fields of hv apparatus and switchgear, power cables and power cable accessories, lv apparatus and switchgear, installation equipment and switching and control equipment.



DAT - P - 019/92