

KEMA REPORT OF PERFORMANCE

1517-15

Object	A three-phase dry-type cast-resin distribution transformer		
Type	TREF-DRY 33/1250	Serial No.	209895
	33 kV +1 x 2,5% -3 x 2,5% / 0,400 kV - 1250 kVA - Dyn11- 50 Hz		
Client	Elkima Elektrik İnşaat Taahhüt Ticaret ve Sanayi Ltd. Şti., Izmir, Turkey		
Manufacturer	Elkima Elektrik İnşaat Taahhüt Ticaret ve Sanayi Ltd. Şti., Izmir, Turkey *)		
Tested by	KEMA Nederland B.V., Arnhem, The Netherlands		
Date of tests	13 to 28 April 2015		
Test specification	The tests have been carried out in accordance with IEC 60076-11 (2004), subclauses 27.4 (Thermal shock test for C2 class transformers) and 26.3.2 (Environmental test, Class E2 transformers).		
Remarks	The object has complied with the relevant requirements of the standard.		

This report applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the manufacturer.

*) as declared by the manufacturer

This report consists of 18 pages in total.

KEMA Nederland B.V.


J.P. Fonteljne
Executive Vice President
KEMA Laboratories



Laboratories

Arnhem, 17 May 2016