

KEMA TYPE TEST CERTIFICATE OF SHORT-CIRCUIT PERFORMANCE

Elkima Elektrik İnşaat Taahhüt Ticaret ve Sanayi Ltd. Şti.

Izmir, Turkey

has successfully passed the type test sequence on a three-phase
cast-resin

distribution transformer

Type: TREF-DRY 33/1250

Rating:

1250 kVA - 33 kV +1 x 2,5%, -3 x 2,5% / 0,400 kV - Dyn11 - 50 Hz

The test object passed the specification of test duties of

IEC 60076-11

The test results are recorded in Certificate No.

2172-15

This Certificate was issued on 2 June 2016.

KEMA Nederland B.V.



J.P. Fonteijne
Executive Vice President
KEMA Laboratories

KEMA

Laboratories

